

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0694:191 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Fire Control Instruments, 301 2<sup>nd</sup> Avenue, Waltham, MA 02451-1133  
Contact: Anthony J. Shalna (781) 471-3000\*

**DESIGN:** Model SNAC and \*SNAC-4 Notification Appliance Expander. Unit is intended to boost the power on an indicating device circuit of a separately listed fire alarm control unit. The SNAC has two notification outputs while the SNAC-4 has four. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Primary 120 VAC, Secondary 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, 1993 edition, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. All troubles must be initiated within 200 seconds. Model SNAC must be used with Air Products & Controls' Model PAM-1 AC relay.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessory for use with separately listed compatible fire alarm control unit.

\*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager